

ANALYTICAL REPORT

Job Number: 420-110530-1
SDG Number: Liberty Elementary
Job Description: Sullivan County BOCES

For:
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Attention: Jesse Morrill

Meredith Ruthven

Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
10/03/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110530-1
SDG Number: Liberty Elementary

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110530-1
SDG Number: Liberty Elementary

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Cusack, Renee	RC
EPA 200.8 Rev.5.4	Pistole, Maria	MP

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110530-1
SDG Number: Liberty Elementary

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110530-1	02B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-2	02-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-3	01B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-4	01-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-5	03B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-6	03-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-7	04B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-8	04-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-9	BB1-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-10	BB1-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-11	GB1-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-12	GB1-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-13	BB2-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-14	BB2-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-15	GB2-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-16	GB2-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-17	KIT-BS	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-18	KIT-HWS	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-19	KIT-DWS	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-20	NUR-BS	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-21	BB3-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-22	BB3-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-23	BB3-S3	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-24	BB3-S4	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-25	BB3-S5	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-26	GB3-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-27	GB3-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-28	GB3-S3	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-29	GB3-S4	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-30	GB3-S5	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-31	12B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-32	12-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-33	13B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-34	13-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-35	14B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-36	14-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-37	10B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-38	10-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-39	BB4-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-40	BB4-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-41	GB4-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-42	GB4-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-43	BB5-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-44	GB5-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-45	28B-S	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-46	BB6-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-110530-1
SDG Number: Liberty Elementary

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110530-47	BB6-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-48	GB6-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-49	GB6-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-50	BB7-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-51	BB7-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-52	GB7-S1	Drinking Water	09/20/2016 0600	09/20/2016 1458
420-110530-53	GB7-S2	Drinking Water	09/20/2016 0600	09/20/2016 1458

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 02B-S
Lab Sample ID: 420-110530-1

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1021		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 02-S
Lab Sample ID: 420-110530-2

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1024		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 01B-S
Lab Sample ID: 420-110530-3

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1028		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 01-S
Lab Sample ID: 420-110530-4

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1031		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 03B-S
Lab Sample ID: 420-110530-5

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1035	
Prep Method: 200			Date Prepared:	09/30/2016 1245	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 03-S
Lab Sample ID: 420-110530-6

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1038	
Prep Method: 200			Date Prepared:	09/30/2016 1245	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 04B-S
Lab Sample ID: 420-110530-7

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1042		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 04-S
Lab Sample ID: 420-110530-8

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1052		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB1-S1
Lab Sample ID: 420-110530-9

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1056		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB1-S2
Lab Sample ID: 420-110530-10

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1059		
Prep Method: 200			Date Prepared: 09/30/2016 1245		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB1-S1
Lab Sample ID: 420-110530-11

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1103	
Prep Method: 200			Date Prepared:	09/30/2016 1245	
Pb	1.49	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB1-S2
Lab Sample ID: 420-110530-12

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1106		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB2-S1
Lab Sample ID: 420-110530-13

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1120		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB2-S2
Lab Sample ID: 420-110530-14

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1124		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.46	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB2-S1
Lab Sample ID: 420-110530-15

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1134		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB2-S2
Lab Sample ID: 420-110530-16

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1138		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: KIT-BS
Lab Sample ID: 420-110530-17

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1141	
Prep Method: 200			Date Prepared:	09/30/2016 1315	
Pb	1.03	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: KIT-HWS
Lab Sample ID: 420-110530-18

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1145		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: KIT-DWS
Lab Sample ID: 420-110530-19

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1148		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	18.5 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: NUR-BS
Lab Sample ID: 420-110530-20

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1152		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB3-S1
Lab Sample ID: 420-110530-21

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1155		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB3-S2
Lab Sample ID: 420-110530-22

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1159		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB3-S3
Lab Sample ID: 420-110530-23

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1202		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB3-S4
Lab Sample ID: 420-110530-24

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				10/01/2016 1206	
Prep Method: 200				09/30/2016 1315	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB3-S5
Lab Sample ID: 420-110530-25

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1217		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB3-S1
Lab Sample ID: 420-110530-26

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1220		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB3-S2
Lab Sample ID: 420-110530-27

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1224		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB3-S3
Lab Sample ID: 420-110530-28

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1227		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB3-S4
Lab Sample ID: 420-110530-29

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1231		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB3-S5
Lab Sample ID: 420-110530-30

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1234		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 12B-S
Lab Sample ID: 420-110530-31

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1238		
Prep Method: 200			Date Prepared: 09/30/2016 1315		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 12-S
Lab Sample ID: 420-110530-32

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1241		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 13B-S
Lab Sample ID: 420-110530-33

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1302		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 13-S
Lab Sample ID: 420-110530-34

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1306		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 14B-S
Lab Sample ID: 420-110530-35

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1309		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 14-S
Lab Sample ID: 420-110530-36

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1313		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 10B-S
Lab Sample ID: 420-110530-37

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1316		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 10-S
Lab Sample ID: 420-110530-38

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1320		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB4-S1
Lab Sample ID: 420-110530-39

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1323		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB4-S2
Lab Sample ID: 420-110530-40

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1327	
Prep Method: 200			Date Prepared:	09/30/2016 1410	
Pb	1.50	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB4-S1
Lab Sample ID: 420-110530-41

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1331	
Prep Method: 200			Date Prepared:	09/30/2016 1410	
Pb	1.11	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB4-S2
Lab Sample ID: 420-110530-42

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1341		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.91	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB5-S1
Lab Sample ID: 420-110530-43

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1345		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB5-S1
Lab Sample ID: 420-110530-44

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1348	
Prep Method: 200			Date Prepared:	09/30/2016 1410	
Pb	1.64	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: 28B-S
Lab Sample ID: 420-110530-45

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1352	
Prep Method: 200			Date Prepared:	09/30/2016 1410	
Pb	2.71	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB6-S1
Lab Sample ID: 420-110530-46

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1355		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB6-S2
Lab Sample ID: 420-110530-47

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1359		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB6-S1
Lab Sample ID: 420-110530-48

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1402		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB6-S2
Lab Sample ID: 420-110530-49

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1406		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB7-S1
Lab Sample ID: 420-110530-50

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/01/2016 1409	
Prep Method: 200			Date Prepared:	09/30/2016 1410	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: BB7-S2
Lab Sample ID: 420-110530-51

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1413		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB7-S1
Lab Sample ID: 420-110530-52

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1744		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-110530-1
Sdg Number: Liberty Elementary

Client Sample ID: GB7-S2
Lab Sample ID: 420-110530-53

Date Sampled: 09/20/2016 0600
Date Received: 09/20/2016 1458
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/01/2016 1758		
Prep Method: 200			Date Prepared: 09/30/2016 1410		
Pb	1.00 U	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Sullivan County BOCES

Job Number:
Sdg Number: Liberty Elementary

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Sullivan County BOCES

Job Number:

Sdg Number: Liberty Elementary

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Sullivan County BOCES

Job Number:

Sdg Number: Liberty Elementary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

CUSTOMER SCIBOGES
ADDRESS 6 Wientk Ave.
Liberty, NY 12754
CITY/STATE/ZIP
CONTACT Jesse Morrill PHONE (845) 295-4028
PROJECT Liberty Elementary
LOCATION
PRJ NUMBER/P.O.#

REPORT # (Lab Use Only)
110530

NOTE: SAMPLE TEMPERATURE UPON RECEIPT MUST BE 4C +/- 2C.
SAMPLE TEMP. **23.5 °C 12#3**

SAMPLE REC'D. ON ICE Y N

pH CHECK Y N

CHLORINE RESIDUAL Y N

NY PUBLIC WATER SUPPLIES

SOURCE ID
ELRP TYPE
FEDERAL ID

ANALYSIS REQUESTED
LEAD

REPORT TYPE: STANDARD ISRA NJ REG NYASP A B OTHER

TURNAROUND: NORMAL QUICK VERBAL

Sample #	DATE	TIME	SAMPLING	COMP (Y/N)	GRAB (Y/N)	MATRIX	Client I.D.
Total # of containers							
			40ml Glass HCL				
			Liter Glass HCL				
			250ml Amber H2SO4				
			Liter Amber Plain				
			250ml Plastic HNO3				
			250ml Plastic NaOH				
			Liter Plastic				
			Liter Plastic H2SO4				
			250ml Plastic Sterile				
			8oz Glass				
			250ml Pl. NaOH/ZnAcc				

MATRIX: DW=DRINKING WATER S=SOIL O=OIL WW=WASTE WATER
SL=SLUDGE GW=GROUND WATER

SAMPLES SUBMITTED FOR ANALYSIS WILL BE SUBJECTED TO THE ENVIROTEST TERMS AND CONDITIONS OF SALE (SHORT FORM) UNLESS ALTERNATE TERMS ARE AGREED IN WRITING.

RELINQUISHED BY	COMPANY	DATE	TIME
Jesse Morrill	SCIBOGES	9/20/16	1458
Jesse Morrill	SCIBOGES	9/20/16	3:00
AMore	ETC	9/20/16	1458

COMMENTS

See Attached
1/3

9/20

110530

	Sample #	Date	Time	AREA	250 ml HNO3	Analysis Requested
1	02B-S	9/20/16	6AM	ROOM #2 BATH SINK		LEAD
2	02-S			ROOM #2 ROOM SINK		
3	01B-S			ROOM #1 BATH SINK		
4	01-S			ROOM #1 ROOM SINK		
5	03B-S			ROOM #3 BATH SINK		
6	03-S			ROOM #3 ROOM SINK		
7	04B-S			ROOM #4 BATH SINK		
8	04-S			ROOM #4 ROOM SINK		
9	BB1-S1			BOYS BATH SINK LEFT- HALL NEAR #3		
10	BB1-S2			BOYS BATH SINK RIGHT- HALL NEAR #3		
11	GB1-S1			GIRLS BATH SINK LEFT- HALL NEAR #3		
12	GB1-S2			GIRLS BATH SINK RIGHT - HALL NEAR #3		
13	BB2-S1			BOYS BATH SINK LEFT- HALL NEAR GYM		
14	BB2-S2			BOYS BATH SINK RIGHT- HALL NEAR GYM		
15	GB2-S1			GIRLS BATH SINK LEFT- HALL NEAR GYM		
16	GB2-S2			GIRLS BATH SINK RIGHT- HALL NEAR GYM		
17	KIT-BS			KITCHEN BATHROOM SINK		
18	KIT-HWS			KITCHEN HANDWASH SINK		
19	KIT-DWS			KITCHEN DISHWASH SINK		
20	NUR-BS			NURSE BATHROOM SINK		
21	BB3-S1			BOYS BATH SINK LEFT- HALL NEAR #7		
22	BB3-S2			BOYS BATH SINK LEFT MID- HALL NEAR #7		
23	BB3-S3			BOYS BATH SINK RIGHT MID-HALL NEAR#7		
24	BB3-S4			BOYS BATH SINK RIGHT- HALL NEAR#7		
25	BB3-S5			BOYS BATH SINK SINGLE- HALL NEAR#7		
26	GB3-S1			GIRLS BATH SINK LEFT-HALL NEAR #6		
27	GB3-S2			GIRLS BATH SINK LEFT MID-HALL NEAR#6		
28	GB3-S3			GIRLS BATH SINK RIGHT MID-HALL NEAR#6		
29	GB3-S4			GIRLS BATH SINK RIGHT-HALL NEAR#6		
30	GB3-S5			GIRLS BATH SINK SINGLE-HALL NEAR#6		
31	12B-S			ROOM #12 BATH SINK		
32	12-S			ROOM #12 ROOM SINK		
33	13B-S			ROOM #13 BATH SINK		
34	13-S			ROOM #13 ROOM SINK		
35	14B-S			ROOM #14 BATH SINK		
36	14-S			ROOM #14 ROOM SINK		
37	10B-S			ROOM #10 BATH SINK		
38	10-S			ROOM #10 ROOM SINK		
39	BB4-S1			BOYS BATH SINK LEFT-HALL NEAR#10		
40	BB4-S2			BOYS BATH SINK RIGHT-HALL NEAR#10		
41	GB4-S1			GIRLS BATH SINK LEFT-HALL NEAR#10		
42	GB4-S2			GIRLS BATH SINK RIGHT-HALL NEAR#10		
43	BB5-S1			UNISEX BATH RIGHT- NEAR#17		
44	GB5-S1			UNISEX BATH LEFT- NEAR#17		

Relinquished by: *[Signature]*
 Received by: *[Signature]* ETC 9/20/16 1458

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Sullivan County BOCES

Job Number: 420-110530-1
SDG Number: Liberty Elementary

Login Number: 110530

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	23.5 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	